

STATEMENT OF COMPLIANCE

DNV Id No:
10339284-A /DNV
Date of issue:
2022-05-10

DNV AS confirms that the

- **Jets Collecting Tank 3000L**

Supplied by

- **Jets Vacuum AS, Myravegen 1, 6060 Hareid, Norway**

Meets the relevant¹⁾ requirements of **NS-EN 12566-1:2016** "Small wastewater treatment systems for up to 50 PT, Part 1: Prefabricated septic tanks.

This statement is based on the evaluation of the following test reports and documentations:

- Test report from Nordisk Emballasje Testing AS (NET) on mechanical testing of Jets Collecting Tank, dated 2014.03.31.
- NET EC Declaration of conformity, Certificate No NET01CE14, dated 2014.06.12
- Jets Collecting tank 3000L Technical data and Installation instruction, dated 2019-06-18
- Jets Declaration of Conformity, dated 2022-03-30

This Statement of Compliance is based on evaluation of input from Jets Vacuum in the period March to May 2022.

Note that Jets Collecting Tank 3000L is a closed tank with a small inlet and is designed for vacuum system drainage and do not have any internal wastewater treatment, and Hydraulic efficiency test is not a relevant part of type and qualification testing.

Any significant changes to the product by the manufacturer will render this Statement of Compliance invalid.

¹⁾ Capacity, access, structural, material, marking and CE documentation.

Issued at **Høvik** on **2022-05-10**

for **DNV**

Bjørn Engh
Principle Engineer

Gustav Heiberg
Head of Section - Structural Integrity Advisory

